



ENVIRONMENTAL SERVICES DEPARTMENT
138 Sweetwater Trail, Winder, Georgia 30680
(770) 867-7978

FSE Name: _____

Owner Name: _____

Address: _____

Phone: _____

Inspector: _____

Date: _____

The City of Winder uses the Uniform Plumbing Code for sizing FOG Interceptors.																												
Calculations	Meals during Peak hours	Flow Rate	Retention Time	Storage Factor	Calculated Interceptor Capacity	FOG INTERCEPTOR REQUIRED																						
	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	X	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	X	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	=	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>																					
1	<p>Number of Meals per Peak Hour:</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Seating/Serving Capacity</td> <td style="width: 30%;">Meal Factor</td> <td style="width: 40%;">Meals during Peak hour</td> </tr> <tr> <td style="text-align: center;"> <div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div> </td> <td style="text-align: center;">X</td> <td style="text-align: center;"> <div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div> </td> </tr> <tr> <td colspan="2"></td> <td style="text-align: center;">=</td> </tr> <tr> <td colspan="2"></td> <td style="text-align: center;"> <div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div> </td> </tr> </table> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Establishment Type:</td> <td style="width: 50%;">Meal Factor: UPC Standard</td> </tr> <tr> <td>Fast Food (45 min)</td> <td style="text-align: center;">1.33</td> </tr> <tr> <td>Restaurant (60 min)</td> <td style="text-align: center;">1.00</td> </tr> <tr> <td>Leisure Dining (90 min)</td> <td style="text-align: center;">0.67</td> </tr> <tr> <td>Dining Club (120 min)</td> <td style="text-align: center;">0.50</td> </tr> </table>					Seating/Serving Capacity	Meal Factor	Meals during Peak hour	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	X	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>			=			<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	Establishment Type:	Meal Factor: UPC Standard	Fast Food (45 min)	1.33	Restaurant (60 min)	1.00	Leisure Dining (90 min)	0.67	Dining Club (120 min)	0.50	Notes:
Seating/Serving Capacity	Meal Factor	Meals during Peak hour																										
<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>	X	<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>																										
		=																										
		<div style="border: 1px solid black; width: 40px; height: 40px; margin: 0 auto;"></div>																										
Establishment Type:	Meal Factor: UPC Standard																											
Fast Food (45 min)	1.33																											
Restaurant (60 min)	1.00																											
Leisure Dining (90 min)	0.67																											
Dining Club (120 min)	0.50																											
2	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Flow Rate: Condition</td> <td style="width: 50%;">Flow Rate:(GPM) UPC Standard</td> </tr> <tr> <td>With a dishwasher</td> <td style="text-align: center;">6 gallons/min</td> </tr> <tr> <td>Without a dishwasher</td> <td style="text-align: center;">5 gallons/min</td> </tr> <tr> <td>Single Service Kitchen</td> <td style="text-align: center;">2 gallons/min</td> </tr> <tr> <td>Food Waste Disposer Only</td> <td style="text-align: center;">1 gallon/min</td> </tr> </table>					Flow Rate: Condition	Flow Rate:(GPM) UPC Standard	With a dishwasher	6 gallons/min	Without a dishwasher	5 gallons/min	Single Service Kitchen	2 gallons/min	Food Waste Disposer Only	1 gallon/min	Notes:												
Flow Rate: Condition	Flow Rate:(GPM) UPC Standard																											
With a dishwasher	6 gallons/min																											
Without a dishwasher	5 gallons/min																											
Single Service Kitchen	2 gallons/min																											
Food Waste Disposer Only	1 gallon/min																											
3	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Retention Time:</td> <td style="width: 50%;">UPC Standard</td> </tr> <tr> <td>Commercial Kitchen Waste</td> <td style="text-align: center;">2.5 hours</td> </tr> <tr> <td>Single Service Kitchen</td> <td style="text-align: center;">1.5 hours</td> </tr> </table>					Retention Time:	UPC Standard	Commercial Kitchen Waste	2.5 hours	Single Service Kitchen	1.5 hours	Notes:																
Retention Time:	UPC Standard																											
Commercial Kitchen Waste	2.5 hours																											
Single Service Kitchen	1.5 hours																											
4	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Storage Factor: Kitchen Type</td> <td style="width: 50%;">UPC Standard Storage Factor</td> </tr> <tr> <td>Fully equipped commercial (Hours of Operation)</td> <td></td> </tr> <tr> <td style="padding-left: 20px;">8 hours</td> <td style="text-align: center;">1.00</td> </tr> <tr> <td style="padding-left: 20px;">12 hours</td> <td style="text-align: center;">1.50</td> </tr> <tr> <td style="padding-left: 20px;">16 hours</td> <td style="text-align: center;">2.00</td> </tr> <tr> <td style="padding-left: 20px;">24 hours</td> <td style="text-align: center;">3.00</td> </tr> <tr> <td style="padding-left: 20px;">Single Service Kitchen</td> <td style="text-align: center;">1.50</td> </tr> </table>					Storage Factor: Kitchen Type	UPC Standard Storage Factor	Fully equipped commercial (Hours of Operation)		8 hours	1.00	12 hours	1.50	16 hours	2.00	24 hours	3.00	Single Service Kitchen	1.50	Notes:								
Storage Factor: Kitchen Type	UPC Standard Storage Factor																											
Fully equipped commercial (Hours of Operation)																												
8 hours	1.00																											
12 hours	1.50																											
16 hours	2.00																											
24 hours	3.00																											
Single Service Kitchen	1.50																											
5	<p>Calculate FOG Interceptor Capacity: Multiply the values obtained from steps 1, 2, 3 and 4. The result is the approximate FOG interceptor size for this application.</p>					Notes:																						
6	<p>Select FOG Interceptor: Using the approximate required liquid capacity from step 5, select an appropriate size As recommended by the manufacturer.</p>					Notes:																						